



NOTES:

- 1.) MATERIAL FOR SCUPPER FRAME AND GRATE SHALL BE HOT ROLLED STEEL CONFORMING TO A.S.T.M. A36.
- 2.) STEEL TUBING SHALL CONFORM TO A.S.T.M. A500 GRADE B.
- 3.) COMPLETE UNIT SHALL BE HOT-DIP GALVANIZED PER A.S.T.M. A123.
- 4.) _____ SCUPPERS REQUIRED.

THANK YOU FOR YOUR ORDER. PLEASE REVIEW THIS DRAWING AND INDICATE YOUR ACCEPTANCE BY SIGNING BELOW.

CONTRACTOR SHALL PROVIDE ADDITIONAL DOWNSPOUT LENGTH
<DIMENSION "A"> = _____

COMPANY: _____

CUSTOMER MUST VERIFY SLAB THICKNESS
<DIMENSION "B"> _____

DATE _____

AUTHORIZED SIGNATURE: _____

THIS DOCUMENT IS THE PROPRIETARY PROPERTY OF SYRACUSE CASTINGS. IT HAS BEEN FURNISHED UPON THE CONDITION THAT IT SHALL NOT BE RELEASED, DUPLICATED, USED, OR DISCLOSED IN WHOLE OR IN PART FOR ANY PURPOSE WITHOUT THE EXPRESS WRITTEN PERMISSION OF SYRACUSE CASTINGS AND SHALL BE CONSIDERED CONFIDENTIAL INFORMATION.

Galvanized Steel
B2 Bridge Scupper

DRAWING # SCUPPERB2-TUBINGB2

Drawn By: TJM DATE: 7/27/09 Revised By: Revised:



Syracuse Castings

Better By Design

P.O. Box 1821
6177 South Bay Rd.
Cicero, N.Y. 13039

Phone # 315-699-2601 Fax # 315-699-2982 www.syracast.com